

# Majura (Northside) Community Centre

3<sup>rd</sup> Quarterly Energy Report – September 2015 to November 2015

## Introduction

This report summarises the energy saving results to date for the Majura Community Centre. The site is currently 9 months into its 12 month monitoring period.

For the 9 months since the CEEP upgrade works, the site has increased its electricity consumption by 12% (compared to the baseline period). The gas consumption has reduced by 19% over the same period.

## Results

*Table 1: Energy savings to date (9 months from March 2015 to November 2015)*

Fuel Type	Baseline period	Monitoring period	Saving achieved
Electricity	95,561.6 kWh	107,136.3 kWh	-11,574.7 kWh
Gas	243,365.0 MJ	198,203.0 MJ	45,162.0 MJ

*Table 2: Other savings to date (9 months from March 2015 to November 2015)*

Category	Saving
Estimated Greenhouse Gas Increase	9.4 tonnes of CO <sub>2</sub> equivalent
Estimated Financial Cost Increase	\$1,625

## Building Tenant Energy Saving Tips

Recommendations for tenants to improve energy efficiencies and increase energy cost savings:

- Ensure that portable electric fan heaters are not in use
- Ensure air conditioners are turned off when rooms are left unoccupied
- Maintain proper switching practices for the lighting system
- Switch off all equipment at the power source.