

# Chifley Health and Wellbeing Hub

2<sup>nd</sup> Quarterly Energy Report – July 2014 to September 2014

## Introduction

This report summarises the energy saving results to date for the Chifley Health and Wellbeing Hub. The site is now 6 months into its 12 month monitoring period.

For the first 6 months since the CEEP upgrade works, the site has reduced its electricity consumption by 19% and gas consumption by 53% (compared to the baseline period).

## Results

*Table 1: Energy savings to date (6 months)*

Fuel Type	Baseline period	Current period	Saving achieved to date
Electricity	106,611 kWh	86,549 kWh	20,062 kWh
Gas	738,783 MJ	349,215 MJ	389,568 MJ

*Table 2: Other savings to date*

Category	Saving
Estimated Greenhouse Gas Saving	47 tonnes of CO <sub>2</sub> equivalent
Estimated Financial Saving	\$12,859

### **Building tenant energy saving tips**

Recommendations for tenants to further improve on building energy efficiencies and increase energy cost savings:-

- Shut down office equipment and appliances when not in use, particularly overnight and on weekends.
- Switch off equipment at power source.

Equipment includes but is not limited to the following:

- Personal computers and laptops
- Multi functional devices (MFD)
- IT Server.