

Southside Community Centre

3rd Quarterly Energy Report – June 2014 to August 2014

Introduction

This report summarises the energy saving results to date for Southside Community Centre. The site is now 9 months into its 12 month monitoring period.

For the first 9 months since the CEEP upgrade works, the site has reduced its electricity consumption by 19% and increased its gas consumption by 19% (compared to the baseline period).

Results

Table 1: Energy savings to date (9 months)

Fuel Type	Baseline period	Current period	Saving achieved to date
Electricity	71,603 kWh	57,761 kWh	13,842 kWh
Gas	316 GJ	376 GJ	-60 GJ

Table 2: Other savings to date

Category	Saving
Estimated Greenhouse Gas Saving	11 tonnes of CO ₂ equivalent
Estimated Financial Saving	\$1,795

Building tenant energy saving tips

Recommendations for tenants to further improve on building energy efficiencies and increase energy cost savings:-

- Shut down office equipment and appliances when not in use, particularly overnight and on weekends.
- Switch off equipment at power source.

Equipment includes but is not limited to the following:

- Personal computers and laptops
- Multi functional devices (MFD)
- IT Server.