

Downer Community Centre

2nd Quarterly Energy Report – July 2015 to September 2015

Introduction

This report summarises the energy saving results to date for Downer Community Centre. The site is currently 6 months into its 12 month monitoring period.

Results

Table 1: Energy savings to date (6 months so far)

Fuel Type	Baseline period	Current period	Saving achieved to date
Electricity	4,553.8 kWh	2,830.3 kWh	1,723.5 kWh
Gas	56,291.1 MJ	42,090.8 MJ	14,200.3 MJ

Table 2: Other savings to date

Category	Saving
Estimated Greenhouse Gas Saving	2.8 tonnes of CO ₂ equivalent
Estimated Financial Saving	\$691

Results

For the 6 months since the CEEP upgrade works, the site has reduced its electricity consumption by 38% and its gas consumption by 25%.

There are no new recommendations to help further improve the site's energy savings.